

PROTEX

Central Heating System Additives



INHIBITED DE-SCALER FOR CENTRAL HEATING SYSTEMS

DIRECTIONS FOR USE

1. Switch off boiler and drain system to remove any loose deposits
2. While refilling the system add Protex De-Scaler carefully.
3. When the system is full again turn on boiler and pump and circulate for four to six hours.
Ensure radiators are vented frequently during this procedure.
4. Drain the system totally. Refill using water, circulate for 10 minutes and drain off in order to rinse.
This rinsing procedure is repeated.
5. Finally refill the system and treat with Protex Inhibitor to prevent against further scale formation and corrosion.
6. Use the self adhesive label to register date of application.

Protex De - Scaler is suitable for use in all new indirect central heating systems including those containing aluminium. Consult Health and Safety data Sheets (attached) before use.



Protex De-Scaler was used in this central heating system to clean and flush out scale and impurities.

Protex De-Scaler is manufactured and supplied by:
Excel Industries, Coolmine Industrial Estate,
Clonsilla Road, Dublin 15, Ireland.
Tel: +353 (0) 1 8118701
Email: sales@excel-industries.com



Please use the self adhesive label
to register date of application.